

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7125-1477:110 Page 1 of 1

CATEGORY: Fire Alarm Device for the Hearing Impaired

LISTEE: Mircom Technologies, Ltd*, 8111 Jane Street, Vaughan, ON, L4K 4L7, Canada
Contact: *Mara Cherubin (888) 660-4655 Fax (888) 660-4113

DESIGN: Models FS240 and FHS240 strobe lights. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 19.2-26.4 VDC
Light Output: 15/75cd, 30/120cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as strobe lights for the hearing impaired when used in conjunction with separately listed compatible fire alarm control units. For indoor use, wall or ceiling mounted in non-sleeping area.

XLF: 7125-0587:111

*Rev. 06-18-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 18, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager